

WIDTH "W"	SIDEROOM "X1"	SIDEROOM "X2"
0 - 4499	183	183
4500 - 5000	208	208

CLEAR HEIGHT "H" (MINIMUM 2000)	HEADROOM "A"	HEADROOM "B1"
0 - 3499	450	600
3500 - 4749	500	600
4750 - 5000	550	675

SIZE OF BLAZEGUARD 2000	CLEARANCE OF GUIDE FROM FLOOR "C"
BELOW 3000 clear width & 3000 clear height	0 (DIMENSION UNAPPLICABLE, ALLOW FOR 10mm FOLG LINEAR METRE IN HEIGHT)
ABOVE 3000 clear width OR 3000 clear height	DIMENSION DIMENSION ALLOW FOR 10mm FOLG LINEAR METRE IN HEIGHT

ORDER No.:-

QUANTITY:-

HANDING:- L/H, R/H


(right hand shown).

MISC.:-

SURROUNDING STRUCTURE:-
 This must be a fire-resistant separating element (to B.S.476 PART 20,21,22: 1987) & have a fire resistance > or = to the doorset itself.
STEEL: the L.P.C recommends, that a critical temperature of 400° C and steel sections with an Hp/A value below 230m² are used for designing fire resistant steel supporting structures.
 Only steel supporting structures designed to these parameters are considered by the Loss Prevention Council to be suitable for supporting roller shutters.
FIXING TO STEELWORK:-
 The guide fixing angles can be fixed directly to the st/wrk & the fire protection protecting the st/wrk applied over the section of guide fixing angle attached to the st/wrk, or, where the protection thickness is 25mm or less, the guide fixing angles can be applied over the fire protection; in the latter case the fixings must be packed out by the thickness of the material by a steel collar having a diameter of 25mm.

OPNG. SIZE (W X H) UPTO	QUANTITY REQUIRED	
	TYPE A	A1
CHAIN OP.		
3000 X 3000	325	1
4500 X 4250	372	2
5000 X 5000	376	3
ELEC OP.		
3000 X 3000	325	1
4500 X 4250	372	2
5000 X 5000	376	3
6000 X 5000	376	5
7000 X 3750	430	6

CANOPY/BARREL SUPPORT BKT:
 The barrel support brackets should be fixed symmetrically with respect to the opening centreline.



CANOPY/BARREL SUPPORT BRACKETS ARE SUPPLIED ON ALL DOORS ABOVE 2200mm. PLEASE SPECIFY WHICH TYPE OF BRACKET YOU REQUIRE. IF TYPE B OR TYPE C SPECIFIED, PLEASE STATE HEADROOM DIMENSION.

ZONE	REV	DESCRIPTION	DATE	APPROVED
00	H	ALTERED TO GAROG MOTOR DETAILS	27/12/07	27/12/07

	CLIENT / SITE		-	
	DESCRIPTION INDUPART CHAIN OPERATED BLAZEGUARD 2008 FACE FIX STEEL GENERAL ARRANGEMENT DETAILS			
indupart	SIZE	CONTRACT No.	DWG NO.	REV
	J		BG013 / 02 (G.A)	H
OWN BY:	S.B./J.E	DATE:	-	